

**Institute for Defence Studies and Analyses**  
**No. 1 Development Enclave, New Delhi-110010**

No. IDSA/A/388//08  
Dated: 04<sup>th</sup> Jan, 2016.

To,

-----  
-----

**Subject: Renovation of Fire Hydrants at IDSA .**

Dear Sir(s),

Quotations are invited for Renovation of fire hydrants as per scope/specifications of works given in Annexure-‘A’ enclosed. Conditions of the order shall be as follows: -

**1. Time Schedule**

The work shall be completed within 30 days from the date of placing of order. A sum of Rs 500 per day will be charged for delay in completion of work. Director General IDSA’s decision in this regard shall be final and binding.

**2. Execution of Work**

The materials supplied and /or incorporated into the work shall be best available and strictly conforming to specifications, ISI Marked if any or wherever specified catalogue , catalogue No., sizes and dimensions as mentioned . The job work shall be executed in best workman like manner according to standard engineering practices to the entire satisfaction of the Director General, IDSA.

**3. Unit Price**

Unit rates quoted for the work shall be deemed to include for all material and labour, tools, plants and accessories, as required for proper execution of work complete in all respects. Any missing minor details which are not spelt out in the description of items but are required for proper completion of job work, shall be deemed to have been taken into account in the quoted rates. The rates shall also include for all taxes, octroi, excise duty, transportation etc. including price escalations, contractor’s overheads and profits. Nothing extra ( except service tax ) shall be admissible on any such account.

**4. Approval of Workmanship**

All the material and workmanship shall be subject to the Director General’s, approval. . The site of work shall be cleared of all debris and un-used materials.

**5.** On completion of the work, the contractor shall inform the Estate Manager in writing with the date of physical completion of work for final approval and issues of completion certificate.

**6. Earnest money & Security Deposit** : The Tenderer should have to deposit a demand draft of Rs 5000/- in favour of IDSA payable at New Delhi as EMD . No Interest will be paid on EMD . The EMD will be adjusted in security deposit which will be 10% of the contract value .The security deposit will released after completion of defect liability period of 12 Months . No interest shall be paid on this amount also .

**7. Defect Liability**

The work completed shall have defect liability period of 12 months from the certified date of completion. The contractor shall rectify, re-do and/or replace all the components/item of works wherein defects have developed during this period under the direction of the Director General at no extra cost.

**8. Submission of quotation**

Appendix 'A' to the quotation duly quoted and signed on all pages along with this letter in token of the acceptance of terms and conditions mentioned herein-before, should be submitted in sealed covers duly marked "quotation for Renovation of Fire Hydrants. No 1 Development Enclave, New Delhi addressed to Estate Manager , IDSA, so as to reach on or before 1500 hrs on 27<sup>th</sup> January 2016. .Late quotation shall not be entertained.

9.. Payment shall be made on satisfactory completion of work.

**10. Dispute Resolution**

Disputes if any, with regards to the interpretation, execution and/or implementation of these terms and conditions shall rest exclusively in the Director General, IDSA whose decision shall be final and binding upon the parties. Disputes, if any, with regard to the decision of the Director General, in this regard, shall be referred to arbitration at the hands of a sole arbitrator to be appointed by IDSA and all proceedings in this regard shall be subjected to the sole and exclusive jurisdiction of courts of competent jurisdiction at New Delhi.

11..Upon acceptance of bid, no sub letting/transfer would be allowed by the operator except with the prior written permission of Director General, IDSA

12..Standard force-majeure conditions would be apply.

13. Bidders are advised to visit the site before Quoting , IDSA will not be responsible for their miscalculation of work or under estimating the scope of work .






*Director General, IDSA reserves the right to accept or reject the lowest or any offer or all offers without assigning any reasons thereto.*




Please acknowledge.

Yours sincerely,

Hemant kumar  
Estate Manager

Annexure-A.

Sl	Description	Qty	Rate	Amount	pictures
1	Supply of Hose Reel of fire Hydrant as per IS 444 type -2 water pressure 10 Kg/cm <sup>2</sup> , T.P 16 kg/cm <sup>2</sup> BP 31 Kg/cm <sup>2</sup> . The length of pipe should be 30 meter long having male & female adopters on both ends . The outer surface of the pipe should be black and inner pipe should be metal strengthen . The reel required with mounting arrangements .(wheels) .The Bore size of pipe shall be 20mm	02 Nos			
2.	Supply and fixing of pressure gauge . The pressure gauge should be dial type –with ½’’ opening. The range of pressure gauge shall be (0-200 ) PSI or 0-14 Kg/cm <sup>2</sup>	04 Nos			
3.	Supply & fixing of Gun Metal gate valve -1/4’’ ISI marked.	1 No			
4.	Replacement of broken glasses of 6mm in existing hydrant	59 Nos			
5.	Supply & fixing of glass gasket 6mm thick in existing sample	59 Nos			

6.	Providing & fixing of gate lock with key after dismantling the old locks from the panel , welding the same and door panel complete finishing the same to proper locking of door	118 Nos			
7.	Welding of MS sheet 2mm thick size 8ftx4ft on the sides of damaged hydrant complete finishing the same for proper enclosing the same for locking arrangement	15 Nos			
8.	Painting of fire hydrant & pipe line with 1coat of red oxide & 2 coats of PO red paint (Enamel)	150 Sq mtr			
9.	Supply & fixing of Door hinges as per site design of fire hydrants including welding	40 Nos			
10.	Supply & fixing of male coupling lugs of hydrants as per site requirement .	12 Nos			
	Total cost Excluding service tax and inclusive of all other taxes				

**Amount in words :**

**Service tax will be paid extra as per prevailing rates .**

**(Contractors are advised to visit the site before Quoting )**